

# Compliance Statement

No. 2020-380

## Screened Permanent Link, Class E<sub>A</sub>

### Company

SOCAMONT Industries  
ZI des Touches  
9 rue des frères Lumière  
53000 LAVAL  
France

### Permanent Link Identification (3 connector model)

#### Horizontal cable:

Platine Réseaux Câble Cat6<sub>A</sub> FFTP LS0H 4 Paires 10 GBit 100ohms AWG23 - PN:6710  
Platine Réseaux Câble Cat6<sub>A</sub> FFTP LS0H 2x4 Paires 10 GBit 100 ohms AWG23 - PN:6711

#### RJ45 connector for telecommunications outlet, consolidation point, and patch panel:

Platine Réseaux Jack COCCINELLE RJ45 Cat6<sub>A</sub> FTP 10GIGA - PN:71009

#### Including use with:

Wall Outlet: Platine Réseaux Plastron 1 entrée inclinée DIM 45 X 45 une entrée - PN:71227  
Patch Panel: Platine Réseaux Panneau non équipé 24 ports FTP à accroche Keystone 1U - PN:71007

#### Generic cabling standards - Class E<sub>A</sub> Permanent Link requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-D:2018

#### Technical report

12024360-02, DANAK-19/21157

#### EC Cabling product ID


5370

#### CS valid until

1 June 2021

This product has been tested by FORCE Technology and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 19 May 2020



Lars Lindskov Pedersen  
Test Manager



Dennis Andersen  
Head of Department

