

Compliance Statement

No. 2020-382

Screened Permanent Link, Class E

Company

SOCAMONT Industries
ZI des Touches
9 rue des frères Lumière
53000 LAVAL
France

Permanent Link Identification (3 connector model)

Horizontal cable:

Platine Réseaux Câble Cat6 FUTP LSZH 4 paires 100 ohms AWG23 - PN: 6700
Platine Réseaux Câble Cat6 FUTP LSZH 2x4 paires 100 ohms AWG23 - PN: 6701

RJ45 screened Jack for Wall Outlet and Patch Panel:

Platine Réseaux Jack COCCINELLE RJ45 Cat6 FTP - PN: 71325

Including use with :

Wall Outlet: Platine Réseaux Plastron 1 entrée inclinée dim 45 X 45 une entrée - PN: 71227
Patch Panel: Platine Réseaux Panneau non équipé 24 ports FTP à accroche Keystone 1U - PN: 71007

Generic cabling standards - Class E Permanent Link requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-D:2018

Technical report

12024360-04, DANAK-19/21159

EC Cabling product ID


5374

CS valid until

1 June 2021

This product has been tested by FORCE Technology and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 19 May 2020



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department



FORCE Technology

Venlighedsvej 4
2970 Hørsholm
Denmark
Tel. +45 43 25 14 00
certification.madebydelta.com